

# REPORT OF DRILLED WELL

**P** Midwest Drilling Co. 182 Hazel Green Co. 35750 10/3/88  
 DRILLING CONTRACTOR License Number Address Zip Code Date  
Three Springs School Norton, Co.  
 PROPERTY OWNER Address (mailing) Zip Code  
Norton, Co. Jackson T2S, R10E approximate loc.  
 WELL LOCATION County Section 1/4 Section Township Range ---or:

Distance and direction from nearest town, community, road junction or other reference point

WELL WILL BE USED FOR:

☒ Private supply

☐ Public supply

☐ Industrial supply

☐ Test well

☐ Irrigation

Other: \_\_\_\_\_

10/3/88  
Estimated starting date

Drilling method: (check)

☐ Cable tool  
☒ Rotary  
☐ Jetted  
☐ Bored

Other: \_\_\_\_\_

6 5/8  
Diameter of well

85'  
Estimated depth

Barry Weaver  
SIGNATURE of Drilling Contractor

Total Depth 82'

Completion Date 10/3/88

Interval	Description of cuttings	Interval	Description of cuttings	Completion date: report depths below ground level					
0-8	overburden			Pump	Type: <input type="checkbox"/> Turb. <input type="checkbox"/> Subm. <input type="checkbox"/> Jet <input type="checkbox"/> Cyl.; Other: _____				
8-36	Clay				Intake depth _____ H.P. _____ Yield <u>12</u> gpm				
36-42	Rock + sand			Capacity	Tested by: <input type="checkbox"/> pumping <input checked="" type="checkbox"/> air lift <input type="checkbox"/> bailer <input type="checkbox"/> none				
42-70	sand				Measured Static Water Level <u>50</u> ft.				
70-82	limestone			Measured pumping level _____ ft. after _____ hrs. pumping _____ gpm					
				Development time prior to testing _____ hrs.					
				Finish	<input type="checkbox"/> Open hole <input type="checkbox"/> Screened <input checked="" type="checkbox"/> Slotted pipe <input type="checkbox"/> Gravel pk.				
					Interval(s) screened: <u>all</u> to _____ ft.				
				_____ to _____; _____ to _____ ft.					
				Packer(s) set at _____ and _____ ft.					
				Screen: diam. _____; Size openings _____					
				Casing	Interval cased	Diam. (Inches)	*Type pipe	*Type couplings	Interval grouted
					<u>0-42</u>	<u>6 5/8</u>	<u>galv.</u>	<u>all</u>	
				*Couplings: Threaded & Coupled (T&C) Welded (W) Threaded & coupled & welded (TC&W)					
				Other: _____					
				*Pipe: Black; PVC; Galv.; Other: _____					
				Quality	Water analysis obtained? (check) <input type="checkbox"/> No <input type="checkbox"/> Bacteriological <input type="checkbox"/> Chemical				
					Analysis by: <input type="checkbox"/> Ala Geol. Surv. <input type="checkbox"/> U.S. Geol. Surv. <input type="checkbox"/> Ala Health Dept. <input type="checkbox"/> Private lab.				
				Signed: <u>Barry Weaver</u>					

\*For deeper well please attach continuation sheet.